

SECTION 080671 – DOOR HARDWARE SCHEDULE

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section references specification sections relating to commercial door hardware for the following:
  - 1. Swinging doors.
  - 2. Sliding Doors.
  - 3. Other doors to the extent indicated.
- B. Commercial door hardware includes, but is not necessarily limited to, the following:
  - 1. Mechanical door hardware.
  - 2. Electromechanical and access control door hardware.
  - 3. Electromechanical and access control door hardware power supplies, back-ups and surge protection.
  - 4. Automatic operators.
  - 5. Cylinders specified for doors in other sections.
- C. Related Sections:
  - 1. Division 08 Section “Door Hardware”.
  - 2. Division 28 Section “Intercom Entry Systems”.
- D. Codes and References: Comply with the version adopted by the Authority Having Jurisdiction.
  - 1. ANSI A117.1 - Accessible and Usable Buildings and Facilities.
  - 2. ICC/IBC - International Building Code.
  - 3. NFPA 70 - National Electrical Code.
  - 4. NFPA 80 - Fire Doors and Windows.
  - 5. NFPA 101 - Life Safety Code.
  - 6. NFPA 105 - Installation of Smoke Door Assemblies.
  - 7. State Building Codes, Local Amendments.
- E. Standards: Reference Related Sections for requirements regarding compliance with applicable industry standards.

### 1.3 SUBMITTALS

- A. Product Data: Manufacturer's product data sheets including installation details, material descriptions, dimensions of individual components and profiles, operational descriptions and finishes.
- B. Door Hardware Schedule: Prepared by or under the supervision of supplier, detailing fabrication and assembly of door hardware, as well as procedures and diagrams. Coordinate the final Door Hardware Schedule with doors, frames, and related work to ensure proper size, thickness, hand, function, and finish of door hardware.
  - 1. Format: Comply with scheduling sequence and vertical format in DHI's "Sequence and Format for the Hardware Schedule."
  - 2. Organization: Organize the Door Hardware Schedule into door hardware sets indicating complete designations of every item required for each door or opening. Organize door hardware sets in same order as in the Door Hardware Sets at the end of Part 3. Submittals that do not follow the same format and order as the Door Hardware Sets will be rejected and subject to resubmission.
  - 3. Content: Include the following information:
    - a. Type, style, function, size, label, hand, and finish of each door hardware item.
    - b. Manufacturer of each item.
    - c. Fastenings and other pertinent information.
    - d. Location of door hardware set, cross-referenced to Drawings, both on floor plans and in door and frame schedule.
    - e. Explanation of abbreviations, symbols, and codes contained in schedule.
    - f. Mounting locations for door hardware.
    - g. Door and frame sizes and materials.
  - 4. Submittal Sequence: Submit the final Door Hardware Schedule at earliest possible date, particularly where approval of the Door Hardware Schedule must precede fabrication of other work that is critical in the Project construction schedule. Include Product Data, Samples, Shop Drawings of other work affected by door hardware, and other information essential to the coordinated review of the Door Hardware Schedule.
- C. Keying Schedule: Prepared under the supervision of the Owner, separate schedule detailing final keying instructions for locksets and cylinders in writing. Include keying system explanation, door numbers, key set symbols, hardware set numbers and special instructions. Owner to approve submitted keying schedule prior to the ordering of permanent cylinders.
- D. Product Test Reports: Indicating compliance with cycle testing requirements, based on evaluation of comprehensive tests performed by manufacturer and witnessed by a qualified independent testing agency.
- E. Operating and Maintenance Manuals: Provide manufacturers operating and maintenance manuals for each item comprising the complete door hardware installation in quantity as required in Division 01, Closeout Submittals. The manual to include the name, address, and contact information of the manufacturers providing the hardware and their nearest service

representatives. The final copies delivered after completion of the installation test to include "as built" modifications made during installation, checkout, and acceptance.

- F. Warranties and Maintenance: Special warranties and maintenance agreements specified in the Related Sections.

#### 1.4 DELIVERY, STORAGE, AND HANDLING

- A. Inventory door hardware on receipt and provide secure lock-up and shelving for door hardware delivered to Project site. Do not store electronic access control hardware, software or accessories at Project site without prior authorization.
- B. Tag each item or package separately with identification related to the final Door Hardware Schedule, and include basic installation instructions with each item or package.
- C. Deliver, as applicable, permanent keys, cylinders, cores, access control credentials, software and related accessories directly to Owner via registered mail or overnight package service. Instructions for delivery to the Owner shall be established at the "Keying Conference".

#### 1.5 WARRANTY

- A. General Warranty: Reference Division 01, General Requirements. Special warranties specified in this Article shall not deprive Owner of other rights Owner may have under other provisions of the Contract Documents and shall be in addition to, and run concurrent with, other warranties made by Contractor under requirements of the Contract Documents.

#### 1.6 MAINTENANCE SERVICE

- A. Maintenance Tools and Instructions: Furnish a complete set of specialized tools and maintenance instructions as needed for Owner's continued adjustment, maintenance, and removal and replacement of door hardware.

### PART 2 - PRODUCTS

#### 2.1 SCHEDULED DOOR HARDWARE

- A. Refer to "PART 3 – EXECUTION" for required specification sections.

### PART 3 - EXECUTION

#### 3.1 DOOR HARDWARE SETS

- A. The door hardware sets represent the design intent and direction of the owner and architect. They are a guideline only and should not be considered a detailed hardware schedule. Discrepancies, conflicting hardware and missing items should be brought to the attention of the architect with corrections made prior to the bidding process. Omitted items not included in a

hardware set should be scheduled with the appropriate additional hardware required for proper application and functionality.

1. Quantities listed are for each pair of doors, or for each single door.
  2. The supplier is responsible for handing and sizing all products.
  3. Where multiple options for a piece of hardware are given in a single line item, the supplier shall provide the appropriate application for the opening.
  4. At existing openings with new hardware the supplier shall field inspect existing conditions prior to the submittal stage to verify the specified hardware will work as required. Provide alternate solutions and proposals as needed.
- B. Products listed in the hardware sets shall be supplied by and in accordance with the requirements described in the specification section as noted for each item.
1. Section 08 71 00 – Door Hardware.
- C. Manufacturer’s Abbreviations:
1. MK - McKinney
  2. PE - Pemko
  3. SU - Securitron
  4. YA - ASSA ABLOY ACCENTRA
  5. YR - ASSA ABLOY ACCENTRA Residential Mechanical
  6. HS - HES
  7. RO - Rockwood
  8. NO - Norton Rixson
  9. DR - DoorBird
  10. OT - Other

**Hardware Sets**

**Set: 1.0**

Doors: 101-E

1 Continuous Hinge	CFM_SLF-HD1 PT x Length Required		PE 087100	
1 Electric Power Transfer	EL-CEPT	630	SU 087100	⚡
1 Rim Exit Device, Nightlatch	6200 B MELR 121NL K680	630	YA 087100	⚡
1 SFIC Core	A600	626	YA 087100	
1 Offset Pull	RM5277 12 x 12HD	US32D	RO 087100	

199 ELM STREET MIXED USE RESIDENTIAL AND COMMERCIAL  
SOMERVILLE, MA

1 Automatic Opener	6331	689	NO 087100	⚡
1 ElectroLynx Harness - Frame	QC-C1500P		MK 087100	⚡
1 ElectroLynx Harness - Door	QC-CXXX (Size as required)		MK 087100	⚡
1 Video Door Station	DoorBird D21 Series [Insert Options] [Finish]	DR 281523		⚡
2 Actuator Wall Switch	700	NO 087100		⚡
1 Position Switch	DPS-M/W-WH	SU 087100		⚡
1 Card Reader	By security vendor.	OT		
1 Power Supply	LSP-12-24	YA 087100		⚡
1 Wiring Diagram	Elevation and Point to Point as Specified			
1 Gasket	Furnished with Aluminum Door/Frame			

Notes: Operational Narrative:

1. Doors normally closed and secure.
2. Authorized access by card reader or intercom system retracting exit device latch for predetermined time limit. Exit device latch can be electrically held retracted for open access.
3. ADA access by actuator switch. In locked condition, actuator energized only upon valid card reader presentation.
4. Egress free for immediate exit. ADA egress by actuator switch.
5. REX switch in push rail allows authorized exit without alarm condition.
6. Door position switch monitor open/closed status.
7. Exit device latch releases (fail secure) in event of power loss. Keyed cylinder override for emergency access.

**Set: 2.0**

Doors: 111-E, 112-E, SB-E

1 Continuous Hinge	CFM_SLF-HD1-M x Length Required		PE 087100	
1 Rim Exit Device, Nightlatch	6100ED 121NL K680	630	YA 087100	
1 SFIC Core	A600	626	YA 087100	
1 Offset Pull	RM5277 12 x 12HD	US32D	RO 087100	
1 Surface Closer	UNI4400	689	YA 087100	
1 Sweep	3452CNB		PE 087100	
1 Threshold	25_x_AFG MSES25SS-2		PE 087100	
1 Gasket	Furnished with Aluminum Door/Frame			

**Set: 3.0**

Doors: R02-E

199 ELM STREET MIXED USE RESIDENTIAL AND COMMERCIAL  
SOMERVILLE, MA

1 Continuous Hinge	CFM_HD1-M x Length Required		PE	087100
1 Rim Exit Device, Classroom	7100 AU626F K680 Less Dog SPAR 05454 (weep holes)	630	YA	087100
1 SFIC Core	A600	626	YA	087100
1 Surface Closer	4400	689	YA	087100
1 Door Stop (straight roller)	456-RKW	US26D	RO	087100
1 Door Bottom	234APK		PE	087100
1 Threshold	25_x_AFG MSES25SS-2		PE	087100
1 Gasket	Furnished with Aluminum Door/Frame			

**Set: 4.0**

Doors: 101

1 Continuous Hinge	CFM_HD1-M x Length Required		PE	087100
1 Push Bar	RM5232	US32D	RO	084126
1 Offset Pull	RM5277 12 x 12HD	US32D	RO	087100
1 Automatic Opener	6331	689	NO	087100 ⚡
1 Door Stop	441CU / 400	US26D	RO	087100
2 Actuator Wall Switch	700		NO	087100 ⚡
1 Gasket	Furnished with Aluminum Door/Frame			

Notes: Operational Narrative:

1. Doors normally closed.
2. ADA access by actuator switch.
3. Egress free for immediate exit. ADA egress by actuator switch.

**Set: 5.0**

Doors: 102

3 Hinge, Full Mortise, Hvy Wt	T4A3786 [NRP]	US26D	MK	087100
1 Rim Exit Device, Exit Only	6100ED A EO B (Alarmed with cylinder)	630	YA	087100 ⚡
1 SFIC Core	A600	626	YA	087100
1 Surface Closer	3501 / P3501	689	YA	087100
1 Kick Plate	K1050 10" high CSK BEV	US32D	RO	087100
1 Gasketing	S88		PE	087100

199 ELM STREET MIXED USE RESIDENTIAL AND COMMERCIAL  
SOMERVILLE, MA

Notes: Operational Narrative:

1. Doors normally closed and secure.
2. Pushing on rail sounds alarm after momentary delay. Cylinder in rail turns on/ off/ resets alarm.
3. Egress free for immediate exit.
4. Exit device latch releases (fail secure) in event of power loss.

**Set: 6.0**

Doors: **1SB**

3 Hinge, Full Mortise, Hvy Wt	T4A3786 [NRP]	US26D	MK	087100
1 Fire Rated Rim Exit, Nightlatch	6100FED AU627F K680	630	YA	087100
1 Surface Closer	3501 / P3501	689	YA	087100
1 Kick Plate	K1050 10" high CSK BEV	US32D	RO	087100
1 Door Stop	409 (or) 441CU (As Required)	US32D	RO	087100
1 Gasketing	S88D (Head & Jambs)		PE	087100
1 Threshold	to architect detail		PE	087100

**Set: 7.0**

Doors: **1SA, 2SA, 2SB, 3SA, 3SB, 4SA, 4SB, RSA**

3 Hinge, Full Mortise, Hvy Wt	T4A3786 [NRP]	US26D	MK	087100
1 Fire Rated Rim Exit, Passage	6100FED AU628F	630	YA	087100
1 Surface Closer	3501 / P3501	689	YA	087100
1 Kick Plate	K1050 10" high CSK BEV	US32D	RO	087100
1 Door Stop	409 (or) 441CU (As Required)	US32D	RO	087100
1 Gasketing	S88D (Head & Jambs)		PE	087100
1 Sweep	315CN		PE	087100
1 Threshold	to architect detail		PE	087100

**Set: 8.0**

Doors: **103**

3 Hinge, Full Mortise	TA2714 [NRP]	US26D	MK	087100
1 Passage Latch	AU 4701LN	626	YA	087100
1 Electric Strike	1500C	630	HS	087100 ⚡
1 Automatic Opener	6331	689	NO	087100 ⚡
1 Kick Plate	K1050 10" high CSK BEV	US32D	RO	087100
1 Door Stop	409 (or) 441CU (As Required)	US32D	RO	087100
1 Gasketing	S773BL		PE	087100
1 Door Bottom	411APKL		PE	087100

199 ELM STREET MIXED USE RESIDENTIAL AND COMMERCIAL  
SOMERVILLE, MA

1 Threshold	to architect detail	PE 087100	
1 ElectroLynx Harness - Frame	QC-C1500P	MK 087100	⚡
1 Motion Sensor	663	NO 087100	⚡
2 Actuator Wall Switch	700	NO 087100	⚡
1 Power Supply	LSP-12-24	YA 087100	⚡
1 Wiring Diagram	Elevation and Point to Point as Specified		

Notes: Operation:

\*Door normally closed and unlocked.

\*Activation of wall switch either side to activate automatic operator.

\*Upon loss of power door to remain unlocked.

\*Always free egress.

**Set: 9.0**

Doors: 1SD, B06, B11, BSC, R01

3 Hinge, Full Mortise	TA2714 [NRP]	US26D MK 087100
1 Storeroom or Closet Lock	B AU 4705LN	626 YA 087100
1 SFIC Core	A600	626 YA 087100
1 Surface Closer	3501 / P3501	689 YA 087100
1 Kick Plate	K1050 10" high CSK BEV	US32D RO 087100
1 Door Stop	409 (or) 441CU (As Required)	US32D RO 087100
3 Silencer	608-RKW	RO 087100

**Set: 10.0**

Doors: R03

3 Hinge, Full Mortise	TA2714 [NRP]	US26D MK 087100
1 Storeroom or Closet Lock	B AU 4705LN	626 YA 087100
1 SFIC Core	A600	626 YA 087100
1 Surface Closer	3501 / P3501	689 YA 087100
1 Kick Plate	K1050 10" high CSK BEV	US32D RO 087100
1 Door Stop	409 (or) 441CU (As Required)	US32D RO 087100
1 Gasketing	S88D (Head & Jambs)	PE 087100

**Set: 11.0**

Doors: 104

199 ELM STREET MIXED USE RESIDENTIAL AND COMMERCIAL  
SOMERVILLE, MA

3 Hinge, Full Mortise	TA2714 [NRP]	US26D MK 087100
1 Passage Latch	AU 4701LN	626 YA 087100
1 Surface Closer	3501 / P3501	689 YA 087100
1 Kick Plate	K1050 10" high CSK BEV	US32D RO 087100
1 Door Stop	409 (or) 441CU (As Required)	US32D RO 087100
1 Gasketing	S88D (Head & Jambs)	PE 087100

**Set: 12.0**

Doors: A1

3 Hinge, Full Mortise	TA2714 [NRP]	US26D MK 087100
1 Entrance or Apartment Lock	AUR3 8847RL A620 Less Core	626 YA 087100
1 SFIC Core	A600	626 YA 087100
1 Surface Closer	3501 / P3501	689 YA 087100
1 Kick Plate	K1050 10" high CSK BEV	US32D RO 087100
1 Door Stop	RM857	US15 RO 087100
1 Gasketing	S88D (Head & Jambs)	PE 087100
1 Door Bottom	234APK	PE 087100
1 Threshold	171A MSES25SS	PE 087100
1 Video Indoor Station	DoorBird A1101	[Finish] DR 281523 ⚡
1 Viewer	627	CRM RO 087100

**Set: 13.0**

Doors: B1, B2

3 Hinges	Furnished with Pre-Hung Door	US26D
1 Privacy Lock	21 AU	626 YR 087100
1 Door Stop	518	US26D RO 087100
1 Hinge Stop	76306 (where door stop cannot be used)	US26D MK 087100

**Set: 14.0**

Doors: C1, C2, L1

3 Hinges	Furnished with Pre-Hung Door	US26D
1 Passage Latch	11 AU	626 YR 087100
1 Door Stop	518	US26D RO 087100
1 Hinge Stop	76306 (where door stop cannot be used)	US26D MK 087100

199 ELM STREET MIXED USE RESIDENTIAL AND COMMERCIAL  
SOMERVILLE, MA

**Set: 15.0**

Doors: C3

1 BiFold Door Hdwe	HF4/100A	PE 087100
2 Pull	853	US32D RO 087100

**Set: 16.0**

Doors: C4

1 Sliding Door Hdwe	HBP200A	PE 087100
2 Flush Pull	872	US26D RO 087100

END OF SECTION 080671

SECTION 081113 - HOLLOW METAL DOORS AND FRAMES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

1. Standard and custom hollow metal doors and frames.
2. Steel sidelight, borrowed lite and transom frames.
3. Louvers installed in hollow metal doors.
4. Light frames and glazing installed in hollow metal doors.

B. Related Sections:

1. Division 01 Section "General Conditions".
2. Division 04 Section "Masonry".
3. Division 06 Section "Rough Carpentry".
4. Division 06 Section "Finish Carpentry".
5. Division 08 Section "Operations and Maintenance".
6. Division 08 Section "Flush Wood Doors".
7. Division 08 Section "Aluminum-Framed Entrances and Storefronts".
8. Division 08 Section "Glazing".
9. Division 08 Section "Door Hardware".
10. Division 09 Sections "Painting".
11. Division 26 Section "Electrical"

C. Codes and References: Comply with the version year adopted by the Authority Having Jurisdiction.

1. ANSI/SDI A250.8 - Recommended Specifications for Standard Steel Doors and Frames.
2. ANSI/SDI A250.4 - Test Procedure and Acceptance Criteria for Physical Endurance for Steel Doors, Frames, Frames Anchors and Hardware Reinforcing.
3. ANSI/SDI A250.6 - Recommended Practice for Hardware Reinforcing on Standard Steel Doors and Frames.
4. ANSI/SDI A250.10 - Test Procedure and Acceptance Criteria for Prime Painted Steel Surfaces for Steel Doors and Frames.
5. ANSI/SDI A250.11 - Recommended Erection Instructions for Steel Frames.
6. ASTM A1008 - Standard Specification for Steel Sheet, Cold-Rolled, Carbon, Structural, High-Strength Low-Alloy and High-Strength Low-Alloy with Improved Formability.

199 ELM STREET MIXED USE RESIDENTIAL AND COMMERCIAL  
SOMERVILLE, MA

7. ASTM A653 - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
8. ASTM A924 - Standard Specification for General Requirements for Steel Sheet, Metallic-Coated by the Hot-Dip Process.
9. SDI-113 Standard Practice for Determining the Steady-State Thermal Transmittance of Steel Door & Frame Assemblies.
10. ASTM C 1363 - Standard Test Method for Thermal Performance of Building Assemblies by Means of a Hot Box Apparatus.
11. ASTM C1199 - Standard Test Method for Measuring the Steady-State Thermal Transmittance of Fenestration Systems Using Hot Box Methods
12. ASTM E1423 - Practice for Determining Steady State Thermal Transmittance of Fenestration Systems.
13. ANSI/BHMA A156.115 - Hardware Preparation in Steel Doors and Frames.
14. ANSI/SDI 122 - Installation and Troubleshooting Guide for Standard Steel Doors and Frames.
15. ANSI/NFPA 80 - Standard for Fire Doors and Fire Windows; National Fire Protection Association.
16. ANSI/NFPA 105: Standard for the Installation of Smoke Door Assemblies.
17. NFPA 252 - Standard Methods of Fire Tests of Door Assemblies; National Fire Protection Association.
18. UL 10C - Positive Pressure Fire Tests of Door Assemblies.
19. UL 1784 - Standard for Air Leakage Tests of Door Assemblies.

1.3 SUBMITTALS

- A. Product Data: For each type of product indicated. Include construction details, material descriptions, core descriptions, hardware reinforcements, profiles, anchors, fire-resistance rating, and finishes.
- B. Door hardware supplier is to furnish templates, template reference number and/or physical hardware to the steel door and frame supplier in order to prepare the doors and frames to receive the finish hardware items.
- C. Shop Drawings: Include the following:
  1. Elevations of each door design.
  2. Details of doors, including vertical and horizontal edge details and metal thicknesses.
  3. Frame details for each frame type, including dimensioned profiles and metal thicknesses.
  4. Locations of reinforcement and preparations for hardware.
  5. Details of anchorages, joints, field splices, and connections.
  6. Details of accessories.
  7. Details of moldings, removable stops, and glazing.
  8. Details of conduit and preparations for power, signal, and control systems.
- D. Samples for Verification:
  1. Samples are only required by request of the architect and for manufacturers that are not current members of the Steel Door Institute.

#### 1.4 QUALITY ASSURANCE

- A. Source Limitations: Obtain hollow metal doors and frames through one source from a single manufacturer wherever possible.
- B. Quality Standard: In addition to requirements specified, furnish SDI-Certified manufacturer products that comply with ANSI/SDI A250.8, latest edition, "Recommended Specifications for Standard Steel Doors and Frames".
- C. Fire-Rated Door Assemblies: Assemblies complying with NFPA 80 that are listed and labeled by a qualified testing agency, for fire-protection ratings indicated, based on testing at positive pressure according to UL10C (neutral pressure at 40" above sill) or UL 10C.
  - 1. Oversize Fire-Rated Door Assemblies Construction: For units exceeding sizes of tested assemblies, attach construction label certifying doors are built to standard construction requirements for tested and labeled fire rated door assemblies except for size.
  - 2. Temperature-Rise Limit: Where indicated and at vertical exit enclosures (stairwell openings) and exit passageways, provide doors that have a maximum transmitted temperature end point of not more than 450 deg F (250 deg C) above ambient after 30 minutes of standard fire-test exposure.
  - 3. Smoke Control Door Assemblies: Comply with NFPA 105.
    - a. Smoke "S" Label: Doors to bear "S" label, and include smoke and draft control gasketing applied to frame and on meeting stiles of pair doors.
- D. Fire-Rated, Borrowed-Light Frame Assemblies: Assemblies complying with NFPA 80 that are listed and labeled, by a testing and inspecting agency acceptable to authorities having jurisdiction, for fire-protection ratings indicated, based on testing according to NFPA 257. Provide labeled glazing material.
- E. Pre-Submittal Conference: Conduct conference in compliance with requirements in Division 01 Section "Project Meetings" with attendance by representatives of Supplier, Installer, and Contractor to review proper methods and procedures for installing hollow metal doors and frames and to verify installation of electrical knockout boxes and conduit at frames with electrified or access control hardware.

#### 1.5 DELIVERY, STORAGE, AND HANDLING

- A. Deliver hollow metal work palletized, wrapped, or crated to provide protection during transit and Project site storage. Do not use non-vented plastic.
- B. Deliver welded frames with two removable spreader bars across bottom of frames, tack welded to jambs and mullions.
- C. Store hollow metal work under cover at Project site. Place in stacks of five units maximum in a vertical position with heads up, spaced by blocking, on minimum 4-inch high wood blocking. Do not store in a manner that traps excess humidity.
  - 1. Provide minimum 1/4-inch space between each stacked door to permit air circulation. Door and frames to be stacked in a vertical upright position.

199 ELM STREET MIXED USE RESIDENTIAL AND COMMERCIAL  
SOMERVILLE, MA

1.6 PROJECT CONDITIONS

- A. Field Measurements: Verify actual dimensions of openings by field measurements before fabrication.

1.7 COORDINATION

- A. Coordinate installation of anchorages for hollow metal frames. Furnish setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors. Deliver such items to Project site in time for installation.
- B. Building Information Modeling (BIM) Support: Utilize designated BIM software tools and obtain training needed to successfully participate in the Project BIM processes. All technical disciplines are responsible for the product data integration and data reliability of their Work into the coordinated BIM applications.

1.8 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace doors that fail in materials or workmanship within specified warranty period.
- B. Warranty includes installation and finishing that may be required due to repair or replacement of defective doors.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, provide steel doors and frames from a SDI Certified manufacturer:
  - 1. CECO Door Products (C).
  - 2. Curries Company (CU).
  - 3. Pioneer Industries (PI).

2.2 MATERIALS

- A. Cold-Rolled Steel Sheet: ASTM A 1008/A 1008M, Commercial Steel (CS), Type B; suitable for exposed applications.
- B. Metallic-Coated Steel Sheet: ASTM A 653/A 653M, Commercial Steel (CS), Type B; with minimum G60 (Z180) or A60 (ZF180) metallic coating.
- C. Frame Anchors: ASTM A 653/A 653M, Commercial Steel (CS), Commercial Steel (CS), Type B; with minimum G60 (Z180) or A60 (ZF180) metallic coating.

## 2.3 HOLLOW METAL DOORS

- A. General: Provide 1-3/4 inch doors of design indicated, not less than thickness indicated; fabricated with smooth surfaces, without visible joints or seams on exposed faces unless otherwise indicated. Comply with ANSI/SDI A250.8 and ANSI/NAAMM HMMA 867.
- B. Interior Doors: Face sheets fabricated of commercial quality cold rolled steel that complies with ASTM A 1008/A 1008M. Provide doors complying with requirements indicated below by referencing ANSI/SDI A250.8 for level and model and ANSI/SDI A250.4 for physical performance level:
  - 1. Design: Flush panel.
  - 2. Core Construction: Manufacturer's standard kraft-paper honeycomb, or one-piece polystyrene core, securely bonded to both faces.
    - a. Fire Door Core: As required to provide fire-protection and temperature-rise ratings indicated.
  - 3. Level/Model: Level 2 and Physical Performance Level B (Heavy Duty), Minimum 18 gauge (0.042-inch - 1.0-mm) thick steel, Model 2.
  - 4. Top and Bottom Edges: Reinforce tops and bottoms of doors with a continuous steel channel not less than 16 gauge, extending the full width of the door and welded to the face sheet.
  - 5. Hinge Reinforcement: Minimum 7 gauge (3/16") plate 1-1/4" x 9" or minimum 14 gauge continuous channel with pierced holes, drilled and tapped.
  - 6. Hardware Reinforcements: Fabricate according to ANSI/SDI A250.6 with reinforcing plates from same material as door face sheets.
- C. Manufacturers Basis of Design:
  - 1. Curries Company (CU) - Polystyrene Core - 707 Series.

## 2.4 HOLLOW METAL FRAMES

- A. General: Comply with ANSI/SDI A250.8 and with details indicated for type and profile.
- B. Interior Frames: Fabricated from cold-rolled steel sheet that complies with ASTM A 1008/A 1008M.
  - 1. Fabricate frames with mitered or coped corners. Profile as indicated on drawings.
  - 2. Frames: Minimum 16 gauge (0.053-inch -1.3-mm) thick steel sheet.
  - 3. Manufacturers Basis of Design:
    - a. Curries Company (CU) - C CM Series.
    - b. Curries Company (CU) - M Series.
- C. Fire rated frames: Fabricate frames in accordance with NFPA 80, listed and labeled by a qualified testing agency, for fire-protection ratings indicated.

199 ELM STREET MIXED USE RESIDENTIAL AND COMMERCIAL  
SOMERVILLE, MA

- D. Hardware Reinforcement: Fabricate according to ANSI/SDI A250.6 Table 4 with reinforcement plates from same material as frames.

## 2.5 FRAME ANCHORS

- A. Jamb Anchors:
  - 1. Masonry Type: Adjustable strap-and-stirrup or T-shaped anchors to suit frame size, formed from A60 metallic coated material, not less than 0.042 inch thick, with corrugated or perforated straps not less than 2 inches wide by 10 inches long; or wire anchors not less than 0.177 inch thick.
  - 2. Stud Wall Type: Designed to engage stud and not less than 0.042 inch thick.
- B. Floor Anchors: Floor anchors to be provided at each jamb, formed from A60 metallic coated material, not less than 0.042 inches thick.
- C. Mortar Guards: Formed from same material as frames, not less than 0.016 inches thick.

## 2.6 LIGHT OPENINGS AND GLAZING

- A. Stops and Moldings: Provide stops and moldings around glazed lites where indicated. Form corners of stops and moldings with butted or mitered hairline joints at fabricator's shop. Fixed and removable stops to allow multiple glazed lites each to be removed independently. Coordinate frame rabbet widths between fixed and removable stops with the type of glazing and installation indicated.
- B. Moldings for Glazed Lites in Doors and Loose Stops for Glazed Lites in Frames: Minimum 20 gauge thick, fabricated from same material as door face sheet in which they are installed.
- C. Fixed Frame Moldings: Formed integral with hollow metal frames, a minimum of 5/8 inch (16 mm) high unless otherwise indicated. Provide fixed frame moldings and stops on outside of exterior and on secure side of interior doors and frames.
- D. Preformed Metal Frames for Light Openings: Manufacturer's standard frame formed of 0.048-inch-thick, cold rolled steel sheet; with baked enamel or powder coated finish; and approved for use in doors of fire protection rating indicated. Match pre-finished door paint color where applicable.

## 2.7 ACCESSORIES

- A. Mullions and Transom Bars: Join to adjacent members by welding or rigid mechanical anchors.
- B. Grout Guards: Formed from same material as frames, not less than 0.016 inches thick.

## 2.8 FABRICATION

- A. Fabricate hollow metal work to be rigid and free of defects, warp, or buckle. Accurately form metal to required sizes and profiles, with minimum radius for thickness of metal. Where practical, fit and assemble units in manufacturer's plant. When shipping limitations so dictate,

199 ELM STREET MIXED USE RESIDENTIAL AND COMMERCIAL  
SOMERVILLE, MA

frames for large openings are to be fabricated in sections for splicing or splining in the field by others.

B. Tolerances: Fabricate hollow metal work to tolerances indicated in ANSI/SDI A250.8.

C. Hollow Metal Doors:

1. Exterior Doors: Provide optional weep-hole openings in bottom of exterior doors to permit moisture to escape where specified.
2. Glazed Lites: Factory cut openings in doors with applied trim or kits to fit. Factory install glazing where indicated.
3. Astragals: Provide overlapping astragals as noted in door hardware sets in Division 08 Section "Door Hardware" on one leaf of pairs of doors where required by NFPA 80 for fire-performance rating or where indicated. Extend minimum 3/4 inch beyond edge of door on which astragal is mounted.
4. Continuous Hinge Reinforcement: Provide welded continuous 12 gauge strap for continuous hinges specified in hardware sets in Division 08 Section "Door Hardware".

D. Hollow Metal Frames:

1. Shipping Limitations: Where frames are fabricated in sections due to shipping or handling limitations, provide alignment plates or angles at each joint, fabricated of same thickness metal as frames.
2. Welded Frames: Weld flush face joints continuously; grind, fill, dress, and make smooth, flush, and invisible.
  - a. Welded frames are to be provided with two steel spreaders temporarily attached to the bottom of both jambs to serve as a brace during shipping and handling. Spreader bars are for bracing only and are not to be used to size the frame opening.
3. Sidelight and Transom Bar Frames: Provide closed tubular members with no visible face seams or joints, fabricated from same material as door frame. Fasten members at crossings and to jambs by butt welding.
4. High Frequency Hinge Reinforcement: Provide high frequency hinge reinforcements at door openings 48-inches and wider with mortise butt type hinges at top hinge locations.
5. Continuous Hinge Reinforcement: Provide welded continuous 12 gauge straps for continuous hinges specified in hardware sets in Division 08 Section "Door Hardware".
6. Provide countersunk, flat- or oval-head exposed screws and bolts for exposed fasteners unless otherwise indicated for removable stops, provide security screws at exterior locations.
7. Mortar Guards: Provide guard boxes at back of hardware mortises in frames at all hinges and strike preps regardless of grouting requirements.
8. Floor Anchors: Weld anchors to bottom of jambs and mullions with at least four spot welds per anchor.
9. Jamb Anchors: Provide number and spacing of anchors as follows:
  - a. Masonry Type: Locate anchors not more than 18 inches from top and bottom of frame. Space anchors not more than 32 inches on-center and as follows:
    - 1) Two anchors per jamb up to 60 inches high.
    - 2) Three anchors per jamb from 60 to 90 inches high.

199 ELM STREET MIXED USE RESIDENTIAL AND COMMERCIAL  
SOMERVILLE, MA

- 3) Four anchors per jamb from 90 to 120 inches high.
  - 4) Four anchors per jamb plus 1 additional anchor per jamb for each 24 inches or fraction thereof above 120 inches high.
- b. Stud Wall Type: Locate anchors not more than 18 inches from top and bottom of frame. Space anchors not more than 32 inches o.c. and as follows:
- 1) Three anchors per jamb up to 60 inches high.
  - 2) Four anchors per jamb from 60 to 90 inches high.
  - 3) Five anchors per jamb from 90 to 96 inches high.
  - 4) Five anchors per jamb plus 1 additional anchor per jamb for each 24 inches or fraction thereof above 96 inches high.
  - 5) Two anchors per head for frames above 42 inches wide and mounted in metal stud partitions.
10. Door Silencers: Except on weatherstripped or gasketed doors, drill stops to receive door silencers. Silencers to be supplied by frame manufacturer regardless if specified in Division 08 Section "Door Hardware".
11. Bituminous Coating: Where frames are fully grouted with an approved Portland Cement based grout or mortar, coat inside of frame throat with a water based bituminous or asphaltic emulsion coating to a minimum thickness of 3 mils DFT, tested in accordance with UL 10C and applied to the frame under a 3rd party independent follow-up service procedure.
- E. Hardware Preparation: Factory prepare hollow metal work to receive template mortised hardware; include cutouts, reinforcement, mortising, drilling, and tapping according to the Door Hardware Schedule and templates furnished as specified in Division 08 Section "Door Hardware."
1. Locate hardware as indicated, or if not indicated, according to ANSI/SDI A250.8.
  2. Reinforce doors and frames to receive non-template, mortised and surface mounted door hardware.
  3. Comply with applicable requirements in ANSI/SDI A250.6 and ANSI/DHI A115 Series specifications for preparation of hollow metal work for hardware.
  4. Coordinate locations of conduit and wiring boxes for electrical connections with Division 26 Sections.

## 2.9 STEEL FINISHES

- A. Prime Finishes: Doors and frames to be cleaned, and chemically treated to insure maximum finish paint adhesion. Surfaces of the door and frame exposed to view to receive a factory applied coat of rust inhibiting shop primer.
1. Shop Primer: Manufacturer's standard, fast-curing, lead and chromate free primer complying with ANSI/SDI A250.10 acceptance criteria; recommended by primer manufacturer for substrate; and compatible with substrate and field-applied coatings.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. General Contractor to verify the accuracy of dimensions given to the steel door and frame manufacturer for existing openings or existing frames (strike height, hinge spacing, hinge back set, etc.).
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.2 PREPARATION

- A. Remove welded in shipping spreaders installed at factory. Restore exposed finish by grinding, filling, and dressing, as required to make repaired area smooth, flush, and invisible on exposed faces.
- B. Prior to installation, adjust and securely brace welded hollow metal frames for square, level, twist, and plumb condition.
- C. Tolerances shall comply with SDI-117 "Manufacturing Tolerances Standard Steel Doors and Frames."
- D. Drill and tap doors and frames to receive non-template, mortised, and surface-mounted door hardware.
- E. Verify tolerances against manufacturers installations instructions for tornado and hurricane storm shelter openings.

#### 3.3 INSTALLATION

- A. General: Install hollow metal work plumb, rigid, properly aligned, and securely fastened in place; comply with Drawings and manufacturer's written instructions.
- B. Hollow Metal Frames: Install hollow metal frames of size and profile indicated. Comply with ANSI/SDI A250.11 and NFPA 80 at fire rated openings.
  - 1. Set frames accurately in position, plumbed, leveled, aligned, and braced securely until permanent anchors are set. After wall construction is complete and frames properly set and secured, remove temporary braces, leaving surfaces smooth and undamaged. Shim as necessary to comply with installation tolerances.
  - 2. Floor Anchors: Provide floor anchors for each jamb and mullion that extends to floor, and secure with post-installed expansion anchors.
  - 3. Masonry Walls: Coordinate installation of frames to allow for solidly filling space between frames and masonry with mortar.
  - 4. Grout Requirements: Do not grout head of frames unless reinforcing has been installed in head of frame. Do not grout vertical or horizontal closed mullion members.

199 ELM STREET MIXED USE RESIDENTIAL AND COMMERCIAL  
SOMERVILLE, MA

- C. Hollow Metal Doors: Fit hollow metal doors accurately in frames, within clearances specified below. Shim as necessary.
  - 1. Non-Fire-Rated Standard Steel Doors:
    - a. Jamb and Head: 1/8 inch plus or minus 1/16 inch.
    - b. Between Edges of Pairs of Doors: 1/8 inch plus or minus 1/16 inch.
    - c. Between Bottom of Door and Top of Threshold: Maximum 3/8 inch.
    - d. Between Bottom of Door and Top of Finish Floor (No Threshold): Maximum 3/4 inch.
  - 2. Fire-Rated Doors: Install doors with clearances according to NFPA 80.
- D. Field Glazing: Comply with installation requirements in Division 08 Section "Glazing" and with hollow metal manufacturer's written instructions.

3.4 ADJUSTING AND CLEANING

- A. Final Adjustments: Check and readjust operating hardware items immediately before final inspection. Leave work in complete and proper operating condition. Remove and replace defective work, including hollow metal work that is warped, bowed, or otherwise unacceptable.
- B. Remove grout and other bonding material from hollow metal work immediately after installation.
- C. Prime-Coat and Painted Finish Touchup: Immediately after erection, sand smooth rusted or damaged areas of prime coat, or painted finishes, and apply touchup of compatible air drying, rust-inhibitive primer, zinc rich primer (exterior and galvanized openings) or finish paint.

3.5 FIELD QUALITY CONTROL

- A. Field Inspection (Punch Report): Reference Division 01 Sections "Closeout Procedures". Produce project punch report for each installed door opening indicating compliance with approved submittals and verification hardware is properly installed, operating and adjusted. Include list of items to be completed and corrected, indicating the reasons or deficiencies causing the Work to be incomplete or rejected.
  - 1. Organization of List: Include separate Door Opening and Deficiencies and Corrective Action Lists organized by Mark, Opening Remarks and Comments, and related Opening Images and Video Recordings.

END OF SECTION 081113

SECTION 087100 - DOOR HARDWARE

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes commercial door hardware for the following:
  - 1. Swinging doors.
  - 2. Sliding doors.
  - 3. Other doors to the extent indicated.
- B. Door hardware includes, but is not necessarily limited to, the following:
  - 1. Mechanical door hardware.
  - 2. Electromechanical door hardware.
  - 3. Automatic operators.
  - 4. Cylinders specified for doors in other sections.
- C. Related Sections:
  - 1. Division 01 Section "General Conditions".
  - 2. Division 06 Section "Rough Carpentry".
  - 3. Division 06 Section "Finish Carpentry".
  - 4. Division 08 Section "Operations and Maintenance".
  - 5. Division 08 Section "Hollow Metal Doors and Frames".
  - 6. Division 08 Section "Flush Wood Doors".
  - 7. Division 08 Section "Aluminum-Framed Entrances and Storefronts".
  - 8. Division 26 Section "Electrical"
  - 9. Division 28 Section "Intercom Entry Systems".
- D. Codes and References: Comply with the version adopted by the Authority Having Jurisdiction.
  - 1. ANSI A117.1 - Accessible and Usable Buildings and Facilities.
  - 2. ICC/IBC - International Building Code.
  - 3. NFPA 70 - National Electrical Code.
  - 4. NFPA 80 - Fire Doors and Windows.
  - 5. NFPA 101 - Life Safety Code.
  - 6. NFPA 105 - Installation of Smoke Door Assemblies.
  - 7. UL/ULC and CSA C22.2 - Standards for Automatic Door Operators Used on Fire and Smoke Barrier Doors and Systems of Doors.

8. State Building Codes, Local Amendments.

E. Standards: All hardware specified herein shall comply with the following industry standards as applicable. Any undated reference to a standard shall be interpreted as referring to the latest edition of that standard:

1. ANSI/BHMA Certified Product Standards - A156 Series.
2. UL10C - Positive Pressure Fire Tests of Door Assemblies.
3. ANSI/UL 294 - Access Control System Units.
4. UL 305 - Panic Hardware.
5. ANSI/UL 437- Key Locks.

### 1.3 SUBMITTALS

A. Product Data: Manufacturer's product data sheets including installation details, material descriptions, dimensions of individual components and profiles, operational descriptions and finishes.

B. Door Hardware Schedule: Prepared by or under the supervision of supplier, detailing, fabrication and assembly of door hardware, as well as procedures and diagrams. Coordinate the final Door Hardware Schedule with doors, frames, and related work to ensure proper size, thickness, hand, function, and finish of door hardware.

1. Format: Comply with scheduling sequence and vertical format in DHI's "Sequence and Format for the Hardware Schedule."
2. Organization: Organize the Door Hardware Schedule into door hardware sets indicating complete designations of every item required for each door or opening. Organize door hardware sets in same order as in the Door Hardware Sets at the end of Part 3. Submittals that do not follow the same format and order as the Door Hardware Sets will be rejected and subject to resubmission.
3. Content: Include the following information:
  - a. Type, style, function, size, label, hand, and finish of each door hardware item.
  - b. Manufacturer of each item.
  - c. Fastenings and other pertinent information.
  - d. Location of door hardware set, cross-referenced to Drawings, both on floor plans and in door and frame schedule.
  - e. Explanation of abbreviations, symbols, and codes contained in schedule.
  - f. Mounting locations for door hardware.
  - g. Door and frame sizes and materials.
  - h. Warranty information for each product.

4. Submittal Sequence: Submit the final Door Hardware Schedule at earliest possible date, particularly where approval of the Door Hardware Schedule must precede fabrication of other work that is critical in the Project construction schedule. Include Product Data, Samples, Shop Drawings of other work affected by door hardware, and other information essential to the coordinated review of the Door Hardware Schedule.

C. Shop Drawings: Details of electrified access control hardware indicating the following:

1. Wiring Diagrams: Upon receipt of approved schedules, submit detailed system wiring diagrams for power, signaling, monitoring, communication, and control of the access control system electrified hardware. Differentiate between manufacturer-installed and field-installed wiring. Include the following:
    - a. Elevation diagram of each unique access controlled opening showing location and interconnection of major system components with respect to their placement in the respective door openings.
    - b. Complete (risers, point-to-point) access control system block wiring diagrams.
    - c. Wiring instructions for each electronic component scheduled herein.
  2. Electrical Coordination: Coordinate with related sections the voltages and wiring details required at electrically controlled and operated hardware openings.
- D. Keying Schedule: After a keying meeting with the owner has taken place prepare a separate keying schedule detailing final instructions. Submit the keying schedule in electronic format. Include keying system explanation, door numbers, key set symbols, hardware set numbers and special instructions. Owner must approve submitted keying schedule prior to the ordering of permanent cylinders/cores.
- E. Informational Submittals:
1. Product Test Reports: Indicating compliance with cycle testing requirements, based on evaluation of comprehensive tests performed by manufacturer and witnessed by a qualified independent testing agency.

#### 1.4 CLOSEOUT SUBMITTALS

- A. Operating and Maintenance Manuals: Provide manufacturers operating and maintenance manuals for each item comprising the complete door hardware installation in quantity as required in Division 01, Closeout Procedures.
- B. Project Record Documents: Provide record documentation of as-built door hardware sets in digital format (.pdf, .docx, .xlsx, .csv) and as required in Division 01, Project Record Documents.

#### 1.5 QUALITY ASSURANCE

- A. Manufacturers Qualifications: Engage qualified manufacturers with a minimum 5 years of documented experience in producing hardware and equipment similar to that indicated for this Project and that have a proven record of successful in-service performance.
- B. Certified Products: Where specified, products must maintain a current listing in the Builders Hardware Manufacturers Association (BHMA) Certified Products Directory (CPD).
- C. Installer Qualifications: A minimum 3 years documented experience installing both standard and electrified door hardware similar in material, design, and extent to that indicated for this Project and whose work has resulted in construction with a record of successful in-service performance.

- D. Door Hardware Supplier Qualifications: Experienced commercial door hardware distributors with a minimum 5 years documented experience supplying both mechanical and electromechanical hardware installations comparable in material, design, and extent to that indicated for this Project. Supplier recognized as a factory direct distributor by the manufacturers of the primary materials with a warehousing facility in Project's vicinity. Supplier to have on staff a certified Architectural Hardware Consultant (AHC) available during the course of the Work to consult with Contractor, Architect, and Owner concerning both standard and electromechanical door hardware and keying.
- E. Source Limitations: Obtain each type and variety of door hardware specified in this section from a single source unless otherwise indicated.
  - 1. Electrified modifications or enhancements made to a source manufacturer's product line by a secondary or third party source will not be accepted.
  - 2. Provide electromechanical door hardware from the same manufacturer as mechanical door hardware, unless otherwise indicated.
- F. Each unit to bear third party permanent label indicating compliance with the referenced testing standards.
- G. Keying Conference: Conduct conference to comply with requirements in Division 01 Section "Project Meetings." Keying conference to incorporate the following criteria into the final keying schedule document:
  - 1. Function of building, purpose of each area and degree of security required.
  - 2. Plans for existing and future key system expansion.
  - 3. Requirements for key control storage and software.
  - 4. Installation of permanent keys, cylinder cores and software.
  - 5. Address and requirements for delivery of keys.
- H. Pre-Submittal Conference: Conduct coordination conference in compliance with requirements in Division 01 Section "Project Meetings" with attendance by representatives of Supplier(s), Installer(s), and Contractor(s) to review proper methods and the procedures for receiving, handling, and installing door hardware.
  - 1. Prior to installation of door hardware, conduct a project specific training meeting to instruct the installing contractors' personnel on the proper installation and adjustment of their respective products. Product training to be attended by installers of door hardware (including electromechanical hardware) for aluminum, hollow metal and wood doors. Training will include the use of installation manuals, hardware schedules, templates and physical product samples as required.
  - 2. Inspect and discuss electrical roughing-in, power supply connections, and other preparatory work performed by other trades.
  - 3. Review sequence of operation narratives for each unique access controlled opening.
  - 4. Review and finalize construction schedule and verify availability of materials.
  - 5. Review the required inspecting, testing, commissioning, and demonstration procedures
- I. At completion of installation, provide written documentation that components were applied according to manufacturer's instructions and recommendations and according to approved schedule.

1.6 DELIVERY, STORAGE AND HANDLING

- A. Inventory door hardware on receipt and provide secure lock-up and shelving for door hardware delivered to Project site. Do not store electronic access control hardware, software or accessories at Project site without prior authorization.
- B. Tag each item or package separately with identification related to the final Door Hardware Schedule, and include basic installation instructions with each item or package.
- C. Deliver, as applicable, permanent keys, cylinders, cores, access control credentials, software and related accessories directly to Owner via registered mail or overnight package service. Instructions for delivery to the Owner shall be established at the "Keying Conference".

1.7 COORDINATION

- A. Templates: Obtain and distribute to the parties involved templates for doors, frames, and other work specified to be factory prepared for installing standard and electrified hardware. Check Shop Drawings of other work to confirm that adequate provisions are made for locating and installing hardware to comply with indicated requirements.
- B. Door and Frame Preparation: Doors and corresponding frames are to be prepared, reinforced and pre-wired (if applicable) to receive the installation of the specified electrified, monitoring, signaling and access control system hardware without additional in-field modifications.

1.8 WARRANTY

- A. General Warranty: Reference Division 01, General Requirements. Special warranties specified in this Article shall not deprive Owner of other rights Owner may have under other provisions of the Contract Documents and shall be in addition to, and run concurrent with, other warranties made by Contractor under requirements of the Contract Documents.
- B. Warranty Period: Written warranty, executed by manufacturer(s), agreeing to repair or replace components of standard and electrified door hardware that fails in materials or workmanship within specified warranty period after final acceptance by the Owner. Failures include, but are not limited to, the following:
  - 1. Structural failures including excessive deflection, cracking, or breakage.
  - 2. Faulty operation of the hardware.
  - 3. Deterioration of metals, metal finishes, and other materials beyond normal weathering.
  - 4. Electrical component defects and failures within the systems operation.
- C. Warranty Period: Unless otherwise indicated, warranty shall be one year from date of Substantial Completion.

## PART 2 - PRODUCTS

### 2.1 MATERIALS

- A. Hardware shall not have any visible manufacturer names on exposed materials, except cylinders, when the door is in a closed position.

### 2.2 BUTT HINGES

- A. Hinges: ANSI/BHMA A156.1 butt hinges with number of hinge knuckles and other options as specified in the Door Hardware Sets.

1. Quantity: Provide the following hinge quantity:
  - a. Two Hinges: For doors with heights up to 60 inches.
  - b. Three Hinges: For doors with heights 61 to 90 inches.
  - c. Four Hinges: For doors with heights 91 to 120 inches.
  - d. For doors with heights more than 120 inches, provide 4 hinges, plus 1 hinge for every 30 inches of door height greater than 120 inches.
2. Hinge Size: Provide the following, unless otherwise indicated, with hinge widths sized for door thickness and clearances required:
  - a. Widths up to 3'0": 4-1/2" standard or heavy weight as specified.
  - b. Sizes from 3'1" to 4'0": 5" standard or heavy weight as specified.
3. Hinge Weight and Base Material: Unless otherwise indicated, provide the following:
  - a. Exterior Doors: Heavy weight, non-ferrous, ball bearing or oil impregnated bearing hinges unless Hardware Sets indicate standard weight.
  - b. Interior Doors: Standard weight, steel, ball bearing or oil impregnated bearing hinges unless Hardware Sets indicate heavy weight.
4. Hinge Options: Comply with the following:
  - a. Non-removable Pins: With the exception of electric through wire hinges, provide set screw in hinge barrel that, when tightened into a groove in hinge pin, prevents removal of pin while door is closed; for all out-swinging lockable doors.
5. Manufacturers:
  - a. McKinney (MK) - TA/T4A Series, 5-knuckle.

### 2.3 CONTINUOUS HINGES

- A. Continuous Geared Hinges: ANSI/BHMA A156.26 Grade 1-600 continuous geared hinge. with minimum 0.120-inch thick extruded 6063-T6 aluminum alloy hinge leaves and a minimum overall width of 4 inches. Hinges are non-handed, reversible and fabricated to template screw locations. Factory trim hinges to suit door height and prepare for electrical cut-outs.

1. Where specified, provide modular continuous geared hinges that ship in two or three pieces and form a single continuous hinge upon installation.
2. Manufacturers:
  - a. Pemko (PE).

#### 2.4 SLIDING AND FOLDING HARDWARE

- A. Sliding and Folding Door Hardware: Hardware is to be of type and design as specified and should conform with ANSI/BHMA A156.14.
  1. Provide sliding door hardware as follows:
    - a. Sliding Bi-Passing Pocket Door Hardware: Provide complete sets consisting of track, hangers, stops, bumpers, floor channel, guides, and accessories indicated.
    - b. Cascading: Provide a bi-parting or single direction telescoping system as required with a minimum 200 lb. per door capacity.
    - c. Bi-folding Door Hardware: Rated for door panels weighing up to 125 lb.
    - d. Pocket Sliding Door Hardware: Rated for doors weighing up to 200 lb.
  2. Manufacturers:
    - a. Pemko (PE).

#### 2.5 POWER TRANSFER DEVICES

- A. Concealed Quick Connect Electric Power Transfers: Provide concealed wiring pathway housing mortised into the door and frame for low voltage electrified door hardware. Furnish with Molex™ standardized plug connectors and sufficient number of concealed wires (up to 12) to accommodate the electrified functions specified in the Door Hardware Sets. Connectors plug directly to through-door wiring harnesses for connection to electric locking devices and power supplies. Wire nut connections are not acceptable.
  1. Manufacturers:
    - a. Pemko (PE) - EL-CEPT Series.
    - b. Securitron (SU) - EL-CEPT Series.
- B. Electric Door Wire Harnesses: Provide electric/data transfer wiring harnesses with standardized plug connectors to accommodate up to twelve (12) wires. Connectors plug directly to through-door wiring harnesses for connection to electric locking devices and power supplies. Provide sufficient number and type of concealed wires to accommodate electric function of specified hardware. Provide a connector for through-door electronic locking devices and from hinge to junction box above the opening. Wire nut connections are not acceptable. Determine the length required for each electrified hardware component for the door type, size and construction, minimum of two per electrified opening.
  1. Provide one each of the following tools as part of the base bid contract:

- a. McKinney (MK) - Electrical Connecting Kit: QC-R001.
  - b. McKinney (MK) - Connector Hand Tool: QC-R003.
2. Manufacturers:
- a. McKinney (MK) - QC-C Series.

## 2.6 DOOR OPERATING TRIM

- A. Door Push Plates and Pulls: ANSI/BHMA A156.6 door pushes and pull units of type and design specified in the Hardware Sets. Coordinate and provide proper width and height as required where conflicting hardware dictates.
1. Push/Pull Plates: Minimum .050 inch thick, size as indicated in hardware sets, with beveled edges, secured with exposed screws unless otherwise indicated.
  2. Door Pull and Push Bar Design: Size, shape, and material as indicated in the hardware sets. Minimum clearance of 2 1/2-inches from face of door unless otherwise indicated.
  3. Offset Pull Design: Size, shape, and material as indicated in the hardware sets. Minimum clearance of 2 1/2-inches from face of door and offset of 90 degrees unless otherwise indicated.
  4. Pulls shall be provided with a 10" clearance from the finished floor on the push side to accommodate wheelchair accessibility.
  5. Fasteners: Provide manufacturer's designated fastener type as indicated in Hardware Sets. When through-bolt fasteners are in the same location as a push plate, countersink the fasteners flush with the door face allowing the push plate to sit flat against the door.
  6. Manufacturers:
    - a. Rockwood (RO).

## 2.7 CYLINDERS AND KEYING

- A. General: Cylinder manufacturer to have minimum (10) years experience designing secured master key systems and have on record a published security keying system policy.
1. Manufacturers:
    - a. ASSA ABLOY ACCENTRA (YA).
- B. Cylinder Types: Original manufacturer cylinders able to supply the following cylinder formats and types:
1. Threaded mortise cylinders with rings and cams to suit hardware application.
  2. Rim cylinders with back plate, flat-type vertical or horizontal tailpiece, and raised trim ring.
  3. Bored or cylindrical lock cylinders with tailpieces as required to suit locks.
  4. Tubular deadlocks and other auxiliary locks.
  5. Mortise and rim cylinder collars to be solid and recessed to allow the cylinder face to be flush and be free spinning with matching finishes.
  6. Keyway: Manufacturer's Standard.

199 ELM STREET MIXED USE RESIDENTIAL AND COMMERCIAL  
SOMERVILLE, MA

- C. Small Format Interchangeable Cores: Provide small format interchangeable cores (SFIC) as specified, core insert, removable by use of a special key; usable with other manufacturers' cylinders.
- D. Keying System: Each type of lock and cylinders to be factory keyed.
  - 1. Supplier shall conduct a "Keying Conference" to define and document keying system instructions and requirements.
  - 2. Furnish factory cut, nickel-silver large bow permanently inscribed with a visual key control number as directed by Owner.
  - 3. New System: Key locks to a new key system as directed by the Owner.
- E. Key Quantity: Provide the following minimum number of keys:
  - 1. Change Keys per Cylinder: Two (2)
  - 2. Master Keys (per Master Key Level/Group): Five (5).
- F. Key Registration List (Bitting List):
  - 1. Provide keying transcript list to Owner's representative in the proper format for importing into key control software.
  - 2. Provide transcript list in writing or electronic file as directed by the Owner.

## 2.8 MORTISE LOCKS AND LATCHING DEVICES

- A. Mortise Locksets, Grade 1 (Heavy Duty): Provide ANSI/BHMA A156.13, Series 1000, Operational Grade 1 Certified Products Directory (CPD) listed mortise locksets. Listed manufacturers shall meet all functions and features as specified herein.
  - 1. Manufacturers:
    - a. ASSA ABLOY ACCENTRA (YA) - 8800FL Series.

## 2.9 CYLINDRICAL LOCKS AND LATCHING DEVICES

- A. Cylindrical Locksets, Grade 1 (Commercial Duty): ANSI/BHMA A156.2, Series 4000, Operational Grade 1 Certified Products Directory (CPD) listed cylindrical locksets. Listed manufacturers shall meet all functions and features as specified herein.
  - 1. Manufacturers:
    - a. ASSA ABLOY ACCENTRA (YA) 4700LN Series.
    - b. Falcon Lock (FA) - T Series.

## 2.10 RESIDENTIAL LOCKING DEVICES

- A. Residential Locking Devices: Provide ANSI A156.2, Series 4000, Grade 2 products (knobs, levers, deadbolts, interconnected, handlesets) as specified.

1. Provide residential locking devices with functions and features as follows:
  - a. Locksets, deadbolts, and handle sets designed to fit ANSI standard door preps.
  - b. Meets UL and ULC Standard 10C Positive Pressure, Fire Test of Door Assemblies.
  - c. Non-handed levers.
  - d. Provide levers of like design and style as specified.
2. Manufacturers:
  - a. ASSA ABLOY ACCENTRA (YA) - Heritage Series.
  - b. Kwikset (KW) - Signature Series.

## 2.11 LOCK AND LATCH STRIKES

- A. Strikes: Provide manufacturer's standard strike with strike box for each latch or lock bolt, with curved lip extended to protect frame, finished to match door hardware set, unless otherwise indicated, and as follows:
  1. Flat-Lip Strikes: For locks with three-piece antifriction latchbolts, as recommended by manufacturer.
  2. Extra-Long-Lip Strikes: For locks used on frames with applied wood casing trim.
  3. Aluminum-Frame Strike Box: Provide manufacturer's special strike box fabricated for aluminum framing.
  4. Double-lipped strikes: For locks at double acting doors. Furnish with retractable stop for rescue hardware applications.
- B. Standards: Comply with the following:
  1. Strikes for Mortise Locks and Latches: BHMA A156.13.
  2. Strikes for Bored Locks and Latches: BHMA A156.2.
  3. Strikes for Auxiliary Deadlocks: BHMA A156.36.
  4. Dustproof Strikes: BHMA A156.16.

## 2.12 ELECTRIC STRIKES

- A. Standard Electric Strikes: Electric strikes conforming to ANSI/BHMA A156.31, Grade 1, for use on non-rated or fire rated openings. Strikes shall be of stainless steel construction tested to a minimum of 1500 pounds of static strength and 70 foot-pounds of dynamic strength with a minimum endurance of 1 million operating cycles. Provide strikes with 12 or 24 VDC capability, fail-secure unless otherwise specified. Where specified provide latchbolt and latchbolt strike monitoring indicating both the position of the latchbolt and locked condition of the strike.
  1. Manufacturers:
    - a. HES (HS) - 1500/1600 Series.

- B. Provide electric strikes with in-line power controller and surge suppressor by the same manufacturer as the strike with the combined products having a five year warranty.

## 2.13 CONVENTIONAL EXIT DEVICES

- A. General Requirements: All exit devices specified herein shall meet or exceed the following criteria:

1. Exit devices shall have a five-year warranty.
2. At doors not requiring a fire rating, provide devices complying with NFPA 101 and listed and labeled for "Panic Hardware" according to UL305. Provide proper fasteners as required by manufacturer including sex nuts and bolts at openings specified in the Hardware Sets.
3. Where exit devices are required on fire rated doors, provide devices complying with NFPA 80 and with UL labeling indicating "Fire Exit Hardware". Provide devices with the proper fasteners for installation as tested and listed by UL. Consult manufacturer's catalog and template book for specific requirements.
4. Except on fire rated doors, provide exit devices with hex key dogging device to hold the pushbar and latch in a retracted position. Provide optional keyed cylinder dogging on devices where specified in Hardware Sets.
5. Devices must fit flat against the door face with no gap that permits unauthorized dogging of the push bar. The addition of filler strips is required in any case where the door light extends behind the device as in a full glass configuration.
6. Lever Operating Trim: Where exit devices require lever trim, furnish manufacturer's heavy duty escutcheon trim with threaded studs for thru-bolts.
  - a. Lock Trim Design: As indicated in Hardware Sets, provide finishes and designs to match that of the specified locksets.
  - b. Where function of exit device requires a cylinder, provide a cylinder (Rim or Mortise) as specified in Hardware Sets.
7. Vertical Rod Exit Devices: Where surface or concealed vertical rod exit devices are used at interior openings, provide as less bottom rod (LBR) unless otherwise indicated. Provide dust proof strikes where thermal pins are required to project into the floor.
8. Narrow Stile Applications: At doors constructed with narrow stiles, or as specified in Hardware Sets, provide devices designed for maximum 2" wide stiles.
9. Dummy Push Bar: Nonfunctioning push bar matching functional push bar.
10. Rail Sizing: Provide exit device rails factory sized for proper door width application.
11. Through Bolt Installation: For exit devices and trim as indicated in Door Hardware Sets.

- B. Conventional Push Rail Exit Devices (Commercial Duty): ANSI/BHMA A156.3, Grade 1 Certified Products Directory (CPD) listed exit devices. Listed manufacturers shall meet all functions and features as specified herein. Listed manufacturers shall meet all functions and features as specified herein.

1. Provide locksets with functions and features as follows:
  - a. Where required by code, provide knurling or abrasive coating on all levers leading to hazardous areas.

- b. Meets UL and CUL Standard 10C Positive Pressure, Fire Test of Door Assemblies with levers that meet A117.1 Accessibility Code.
  - c. Five-year limited warranty for mechanical features.
2. Manufacturers:
- a. ASSA ABLOY ACCENTRA (YA) - 6000 Series.
  - b. Falcon (FA) - 24/25 Series.

## 2.14 SURFACE DOOR CLOSERS

### A. All door closers specified herein shall meet or exceed the following criteria:

- 1. General: Door closers to be from one manufacturer, matching in design and style, with the same type door preparations and templates regardless of application or spring size. Closers to be non-handed with full sized covers.
- 2. Standards: Closers to comply with UL-10C for Positive Pressure Fire Test and be U.L. listed for use of fire rated doors.
- 3. Size of Units: Comply with manufacturer's written recommendations for sizing of door closers depending on size of door, exposure to weather, and anticipated frequency of use. Where closers are indicated for doors required to be accessible to the Americans with Disabilities Act, provide units complying with ANSI ICC/A117.1.
- 4. Closer Arms: Provide heavy duty, forged steel closer arms unless otherwise indicated in Hardware Sets.
- 5. Closers shall not be installed on exterior or corridor side of doors; where possible install closers on door for optimum aesthetics.
- 6. Closer Accessories: Provide door closer accessories including custom templates, special mounting brackets, spacers and drop plates as required for proper installation. Provide through-bolt and security type fasteners as specified in the hardware sets.

### B. Door Closers, Surface Mounted (Heavy Duty): ANSI/BHMA A156.4, Grade 1 Certified Products Directory (CPD) listed surface mounted, heavy duty door closers with complete spring power adjustment, sizes 1 thru 6; and fully operational adjustable according to door size, frequency of use, and opening force. Closers to be rack and pinion type, one piece cast iron or aluminum alloy body construction, with adjustable backcheck and separate non-critical valves for closing sweep and latch speed control. Provide non-handed units standard.

- 1. Heavy duty surface mounted door closers shall have a 30-year warranty.
- 2. Manufacturers:
  - a. ASSA ABLOY ACCENTRA (YA) - 4400 Series.
  - b. Corbin Russwin Hardware (RU) - DC6000 Series.
  - c. Norton Rixson (NO) - 7500 Series.

### C. Door Closers, Surface Mounted (Unitrol): ANSI/BHMA A156.4, Grade 1 Certified Products Directory (CPD) listed surface mounted closers with door stop mechanism to absorb dead stop shock on arm and top hinge. Hold-open arms to have a spring loaded mechanism in addition to

shock absorber assembly. Arms to be provided with rigid steel main arm and secondary arm lengths proportional to the door width.

1. Manufacturers:
  - a. ASSA ABLOY ACCENTRA (YA) - Unitrol Series.
  - b. Corbin Russwin Hardware (RU) - Unitrol Series.
  - c. Norton Rixson (NO) - Unitrol Series.

- D. Door Closers, Surface Mounted (Commercial Duty): ANSI/BHMA 156.4, Grade 1 Certified Products Directory (CPD) listed surface mounted, institutional grade door closers with complete spring power adjustment, sizes 1 thru 6; and fully operational adjustable according to door size, frequency of use, and opening force. Closers to be rack and pinion type, one piece cast iron or aluminum alloy body construction, with adjustable backcheck, closing sweep, and latch speed control valves. Provide non-handed units standard.

1. Manufacturers:
  - a. ASSA ABLOY ACCENTRA (YA) - 3500 Series.
  - b. Corbin Russwin Hardware (RU) - DC6000 Series.
  - c. Norton Rixson (NO) - 8500 Series.

## 2.15 ELECTROMECHANICAL DOOR OPERATORS

- A. Electromechanical Door Operators (High Traffic): Provide ANSI/BHMA A156.19 Certified Products Directory (CPD) listed low energy operators that are UL325/991 and UL10C certified and comply with requirements for the Americans with Disabilities Act (ADA). Operators shall accommodate openings up to 250 pounds and 48" wide. Provide accessories such as custom templates, special mounting brackets, spacers and drop plates as needed for proper installation. Operators shall accommodate openings up to 200 pounds and 48" wide. Listed manufacturers shall meet all functions and features as specified herein.

1. Provide operators with features as follows:
  - a. Non-handed with push and pull side mounting.
  - b. Activation by push button, hands-free or radio frequency devices.
  - c. Adjustable opening force and closing power.
  - d. Two-year limited warranty.
  - e. Wi-Fi interface where the operator is a secure, password protected WiFi hot spot with no connection to building's IT required.
    - 1) Simple setup with no app required.
    - 2) View status and make adjustments without removing the cover.
    - 3) Built-in logic to support single use restroom applications with no external relay boards, logic modules, position switches required.
  - f. Mounting backplate to simplify and speed up installation.
  - g. Integration with access control systems.
2. Operators shall have the following functionality:

- a. Adjustable Hold Open: Amount of time a door will stay in the full open position after an activation.
  - b. Blow Open for Smoke Ventilation: Door opens when signal is received from alarm system allowing air or smoke to flow through opening. Door will stay open until signal from alarm system is stopped.
  - c. Emergency Interface Relay: Door closes and ignores any activation input until signal is discontinued.
  - d. Infinite Hold Open: Door will hold open at set position until power is turned off.
  - e. Latch Assist: At closed position, after an activation, the door is pulled in. After the door has closed, the door is pulled in to assist with latch release/engagement.
  - f. Obstruction Detection: Door closes if it hits an obstruction while opening; door will reverse to open position if it hits an obstruction while closing. Door will stop once it hits an obstruction and will rest against the obstruction until removed.
  - g. Open Delay: Delays operator opening for locking hardware.
  - h. Outside Wall Switch Disable: When contact is closed, outside wall switch is disabled.
  - i. Power Assist: Senses the door is being opened manually and applies small amount of power to assist the user in opening the door with force less than 5 lbs. The door opens only as far as it is moved manually, then closes once released.
  - j. Power Close: Additional force to assist door closing between 7° and 2°.
  - k. Presence Detector Input: Input for external sensor to detect presence at door open or close position only.
  - l. Push & Go: As the door is manually opened, the operator "senses" movement and opens door to the full-open position.
  - m. Selector Mode Switch: Off disables the signal inputs unless Blow Open is activated, on activates the signal inputs, hold open activates the unit (unless Blow Closed is activated) to the hold open position.
  - n. Vestibule Delay: When the wall switch is pressed, first door in vestibule will open. Second door will open once vestibule door delay has expired. Delay is adjustable.
  - o. Executive Mode Feature: When the door receives an activation signal it opens and remains open until either a second signal is received, or the door is manually moved in closing direction.
3. Manufacturers:
- a. Norton Rixson (NO) - 6300 Series.

## 2.16 ARCHITECTURAL TRIM AND ACCESSORIES

- A. Door, Frame and Wall Protective Trim: ANSI/BHMA A156.6, protective products as specified in the hardware sets. Door protection plates shall be not more than 2" less than door width on stop side and 1" less door width on the pull side or on stop side of pairs of doors. Listed manufacturers shall meet all functions and features as specified herein.
  1. Provide protective trim with functions and features as follows:
    - a. Meets ADA requirements for smooth bottom door surfaces.
    - b. UL Classified options for use on fire-rated doors up to 3 hours.
    - c. Fabricated from stainless steel, brass, bronze, aluminum, or high-impact plastic.

- d. Available in a variety of sizes, finishes, and profiles to suit aesthetic and functional requirements.
- e. Designed to protect doors, frames, and adjacent walls from damage due to impact, abrasion, or traffic.
- f. Fasteners included; adhesive-backed options available for select models.
- g. Ten-year limited warranty.

2. Manufacturers:

- a. Rockwood (RO).

2.17 DOOR STOPS AND HOLDERS

- A. Door Stops and Bumpers: ANSI/BHMA A156.16, Grade 1 door stops and wall bumpers. Provide wall bumpers, either convex or concave types with anchorage as indicated, unless floor or other types of door stops are specified in Hardware Sets. Do not mount floor stops where they will impede traffic. Where floor or wall bumpers are not appropriate, provide overhead type stops and holders.

1. Manufacturers:

- a. Rockwood (RO).

2.18 ARCHITECTURAL SEALS

- A. General: Thresholds, weatherstripping, and gasket seals to be of type and design as specified below or in the Hardware Sets. Provide continuous weatherstrip gasketing on exterior doors and provide smoke, light, or sound gasketing on interior doors where indicated. At exterior applications provide non-corrosive fasteners and elsewhere where indicated.

- B. Smoke Labeled Gasketing: Assemblies complying with NFPA 105 that are listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for smoke control ratings indicated, based on testing according to UL 1784.

- 1. Provide smoke labeled perimeter gasketing at all smoke labeled openings.

- C. Fire Labeled Gasketing: Assemblies complying with NFPA 80 that are listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for fire ratings indicated, based on testing according to UL-10C.

- 1. Provide intumescent seals as indicated to meet UL10C Standard for Positive Pressure Fire Tests of Door Assemblies, and NFPA 252, Standard Methods of Fire Tests of Door Assemblies.

- D. Sound-Rated Gasketing: Assemblies that are listed and labeled by a testing and inspecting agency, for sound ratings indicated.

- E. Replaceable Seal Strips: Provide only those units where resilient or flexible seal strips are easily replaceable and readily available from stocks maintained by manufacturer.

F. Manufacturers:

1. Pemko (PE).

2.19 ELECTRONIC ACCESSORIES

- A. Door Position Switches: Door position magnetic reed contact switches specifically designed for use in commercial door applications. On recessed models the contact and magnetic housing snap-lock into a 1" diameter hole. Surface mounted models include wide gap distance design complete with armored flex cabling. Provide SPDT, N/O switches with optional Rare Earth Magnet installation on steel doors with flush top channels.

1. Manufacturers:

- a. Alarm Controls (AK) - CP1-1026 Series.
- b. Securitron (SU) - DPS Series.

- B. Linear Power Supplies: Filtered and regulated power for electrified hardware. Listed manufacturers shall meet all functions and features as specified herein.

1. Provide power supplies with functions and features as follows:

- a. 120VAC input with selectable output at 12VDC (6 amp) or 24VDC (3 amp).
- b. Internal back-up battery (batteries not included) charging circuit.
- c. Regulated and filtered, fuse protected outputs.
- d. Each output can be individually turned on and off via a jumper.
- e. Power status of each output is shown by an LED.
- f. Fire alarm interface; dry contacts NO/NC, 9-33VDC, 3-15mA.

2. Manufacturers:

- a. Sargent (SA) - LSP Series.

2.20 FABRICATION

- A. Fasteners: Provide door hardware manufactured to comply with published templates generally prepared for machine, wood, and sheet metal screws. Provide screws according to manufacturers recognized installation standards for application intended.

2.21 FINISHES

- A. Standard: Designations used in the Hardware Sets and elsewhere indicate hardware finishes complying with ANSI/BHMA A156.18, including coordination with traditional U.S. finishes indicated by certain manufacturers for their products.
- B. Provide quality of finish, including thickness of plating or coating (if any), composition, hardness, and other qualities complying with manufacturer's standards, but in no case less than specified by referenced standards for the applicable units of hardware

- C. Protect mechanical finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine scheduled openings, with Installer present, for compliance with requirements for installation tolerances, labeled fire door assembly construction, wall and floor construction, and other conditions affecting performance.
- B. Notify architect of any discrepancies or conflicts between the door schedule, door types, drawings and scheduled hardware. Proceed only after such discrepancies or conflicts have been resolved in writing.

#### 3.2 PREPARATION

- A. Hollow Metal Doors and Frames: Comply with ANSI/DHI A115 series.
- B. Wood Doors: Comply with ANSI/DHI A115-W series.

#### 3.3 INSTALLATION

- A. Install each item of mechanical and electromechanical hardware and access control equipment to comply with manufacturer's written instructions and according to specifications.
  - 1. Installers are to be trained and certified by the manufacturer on the proper installation and adjustment of fire, life safety, and security products including: hanging devices; locking devices; closing devices; and seals.
- B. Mounting Heights: Mount door hardware units at heights indicated in following applicable publications, unless specifically indicated or required to comply with governing regulations:
  - 1. Standard Steel Doors and Frames: DHI's "Recommended Locations for Architectural Hardware for Standard Steel Doors and Frames."
  - 2. DHI TDH-007-20: Installation Guide for Doors and Hardware.
  - 3. Where indicated to comply with accessibility requirements, comply with ANSI A117.1 "Accessibility Guidelines for Buildings and Facilities."
  - 4. Provide blocking in drywall partitions where wall stops or other wall mounted hardware is located.
- C. Retrofitting: Install door hardware to comply with manufacturer's published templates and written instructions. Where cutting and fitting are required to install door hardware onto or into surfaces that are later to be painted or finished in another way, coordinate removal, storage, and reinstallation of surface protective trim units with finishing work specified in Division 9 Sections. Do not install surface-mounted items until finishes have been completed on substrates involved.

- D. Push Plates and Door Pulls: When through-bolt fasteners are in the same location as a push plate, countersink the fasteners flush with the door face allowing the push plate to sit flat against the door.
- E. Thresholds: Set thresholds for exterior and acoustical doors in full bed of sealant complying with requirements specified in Division 7 Section "Joint Sealants."
- F. Storage: Provide a secure lock up for hardware delivered to the project but not yet installed. Control the handling and installation of hardware items so that the completion of the work will not be delayed by hardware losses before and after installation.

### 3.4 FIELD QUALITY CONTROL

- A. Field Inspection (Punch Report): Reference Division 01 Sections "Closeout Procedures". Produce project punch report for each installed door opening indicating compliance with approved submittals and verification hardware is properly installed, operating and adjusted. Include list of items to be completed and corrected, indicating the reasons or deficiencies causing the Work to be incomplete or rejected.
  - 1. Organization of List: Include separate Door Opening and Deficiencies and Corrective Action Lists organized by Mark, Opening Remarks and Comments, and related Opening Images and Video Recordings.

### 3.5 ADJUSTING

- A. Initial Adjustment: Adjust and check each operating item of door hardware and each door to ensure proper operation or function of every unit. Replace units that cannot be adjusted to operate as intended. Adjust door control devices to compensate for final operation of heating and ventilating equipment and to comply with referenced accessibility requirements.

### 3.6 CLEANING AND PROTECTION

- A. Protect all hardware stored on construction site in a covered and dry place. Protect exposed hardware installed on doors during the construction phase. Install any and all hardware at the latest possible time frame.
- B. Clean adjacent surfaces soiled by door hardware installation.
- C. Clean operating items as necessary to restore proper finish. Provide final protection and maintain conditions that ensure door hardware is without damage or deterioration at time of owner occupancy.

### 3.7 DEMONSTRATION

- A. Instruct Owner's maintenance personnel to adjust, operate, and maintain mechanical and electromechanical door hardware.

3.8 DOOR HARDWARE SETS

- A. The hardware sets represent the design intent and direction of the owner and architect. They are a guideline only and should not be considered a detailed hardware schedule. Discrepancies, conflicting hardware and missing items should be brought to the attention of the architect with corrections made prior to the bidding process. Omitted items not included in a hardware set should be scheduled with the appropriate additional hardware required for proper application and functionality.
1. Quantities listed are for each pair of doors, or for each single door.
  2. The supplier is responsible for handing and sizing all products.
  3. Where multiple options for a piece of hardware are given in a single line item, the supplier shall provide the appropriate application for the opening.
  4. At existing openings with new hardware the supplier shall field inspect existing conditions prior to the submittal stage to verify the specified hardware will work as required. Provide alternate solutions and proposals as needed.
- B. Refer to Section 080671, Door Hardware Sets, for hardware sets.

END OF SECTION 087100

SECTION 281523 - INTERCOM ENTRY SYSTEMS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes multi-tenant video intercom entry systems and related products.
- B. Related Sections:
  - 1. Division 01 Section "Closeout Procedures".
  - 2. Division 28 Section "Security Access Detection Equipment".
  - 3. Division 28 Section "Security Video Intercom System".
- C. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.
- D. Codes, References and Standards:
  - 1. American National Standards Institute (ANSI/TIA/EIA) 568 - Commercial Building Telecommunications Cabling Standard.
  - 2. International Organization for Standards (ISO) 9001:2000 - Quality Management Systems - Requirements.

1.3 SUBMITTALS

- A. Product Data: Manufacturer's data sheets on each product to be used, including Preparation instructions and recommendations, storage and handling requirements and recommendations and installation methods.
- B. Shop Drawings: Submittals to include wiring diagrams indicating wiring for each item of equipment and interconnections between items of equipment. Include manufacturer's names, model numbers, ratings, power requirements, equipment layout, device arrangement, complete wiring point-to-point diagrams, and conduit layouts.
- C. Installation and Operation Manuals: Submit manufacturer's installation and operation manual, including operation instructions and component wiring diagrams. Provide detailed information required for Owner to properly operate equipment.
- D. Warranty: Submit manufacturer's standard warranty.

199 ELM STREET MIXED USE RESIDENTIAL AND COMMERCIAL  
SOMERVILLE, MA

1.4 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Engage a qualified manufacturer that is an ISO 9001 (2008) certified company.
- B. Installer Qualifications: Factory trained and experienced with system installations of scope and size required for the Project.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Deliver materials to site in manufacturer's original, unopened containers and packaging, with labels clearly identifying product name and manufacturer.
- B. Store materials in clean, dry area indoors in accordance with manufacturer's instructions.
- C. Protect materials during handling and installation to prevent damage.

1.6 PROJECT CONDITIONS

- A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

PART 2 - PRODUCTS

2.1 INTERCOM ENTRY STATIONS

- A. Door Stations (Multi-Tenant, Large Occupancy): Modern, rectangular surface or flush mounted IP video door stations for multi-tenant residences and buildings with up to 500 units.
  - 1. Manufacturers:
    - a. DoorBird (DR) - D21 Series.
- B. Indoor Stations: Single-family or multi-tenant door communication IP video stations.
  - 1. Provide door stations with the following functions and features:
    - a. Scratch-resistant tempered Gorilla glass 4" true color touch display.
    - b. Visitor history with cloud recording.
    - c. Three relays for door release.
    - d. Two-way HD audio up to 102 dB.
    - e. Room-to-room communication with multiple indoor stations.
    - f. Home and building automation control.
  - 2. Manufacturers:
    - a. DoorBird (DR) - A1100 Series.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine areas to receive integrated security and communication system and notify architect of conditions that would adversely affect installation or subsequent use. Do not begin installation until unacceptable conditions are corrected.

#### 3.2 PREPARATION

- A. Verify the following compliance before starting installation.
  - 1. All units, except for the entrance station and tenant station, are designed for indoor use only.
  - 2. The unit turns inoperative during power failure.
  - 3. In areas where broadcasting station antennas are close by, intercom system may be affected by radio frequency interference.
  - 4. Keep the intercom wires at least 1 foot away from strong electrical wiring including wiring for inverter electrical appliances; noise and malfunction could result.
  - 5. Keep the unit more than 3.3 feet away from radio or TV set.
  - 6. If a strong light shines on the main unit screen, the picture will turn white or only silhouettes will be visible.
  - 7. Other manufacturer's devices (such as sensor, detectors, door releases) used with this system, comply with the manufacturer's installation requirements.

#### 3.3 INSTALLATION

- A. Install integrated security and communication system in accordance with manufacturer's instructions at locations indicated on the Drawings.
- B. Mount equipment plumb, level, square, and secure. For video entrance stations and video door stations, comply with manufacturer's design requirements to provide optimum picture quality of station monitoring.

#### 3.4 SETUP AND ADJUSTING

- A. Adjust integrated security and communication system for proper operation in accordance with manufacturer's instructions.

#### 3.5 DEMONSTRATION AND TRAINING

- A. Demonstrate that integrated security and communication systems function properly.
  - 1. Perform demonstration at final system inspection by qualified representative of manufacturer.
- B. Provide instruction and training of Owner's personnel as required for operation of integrated security and communication system.

199 ELM STREET MIXED USE RESIDENTIAL AND COMMERCIAL  
SOMERVILLE, MA

- C. Provide hands-on demonstration of operation of system components and complete system, including user-level program changes and functions.
- D. Provide instruction and training by qualified representative of manufacturer.

3.6 PROTECTION

- A. Protect installed integrated security and communication system from damage during construction.

END OF SECTION 281523